



ROOT CAUSE ANALYSIS

Identification: At approximately 02:05 EDT, on Sunday, 6/21/15, a portion of the TierPoint Philadelphia power circuits experienced a power disruption, during a scheduled PDU maintenance and EPO integration.

Symptom identification: Power loss was experienced by some of the equipment in the facility.

Apparent cause: Emergency Power Off (EPO) system failure during maintenance.

Resolution: Power was restored as of 02:35 EDT. Systems are currently operating in a normal state.